



PLATFORM
ZERO INCIDENTS



BEST PRACTICE FIRE PREVENTION & FIGHTING

Revision 0

DISCLAIMER

The information in this document was drawn up with the highest possible accuracy. However, the Platform Zero Incidents and its participants cannot be held liable in any way for its content. Adopting measures, suggestions, warnings, etc. must therefore always be preceded by weighing up and risk assessment. Spreading this document among third parties is allowed provided that this is done in the original form.

OVER HET PLATFORM ZERO INCIDENTS

The Platform Zero Incidents (PZI) is an initiative of the inland shipping industry. As the name suggests, PZI aims at 0 (zero) accidents in the inland shipping industry. PZI wants to achieve this by:

- 🚩 Being a Platform in which near misses and incidents are shared among its members.
- 🚩 Preventing repetition of near misses/incidents by developing best practices and stimulating their use, based on research and analysis of near-miss/incident (trends).
- 🚩 Building lasting relationships with stakeholders.
- 🚩 Raising awareness and responsibility for safety within the industry.
- 🚩 Being the center of expertise in the field of preventing safety and environmental incidents in the inland shipping industry.

This publication helps to achieve PZI's mission and vision. The document has been developed by and for inland navigation.

It can be used for various purposes, such as:

- 🚩 Reference for crew members and fleet managers.
- 🚩 Training of crew members.
- 🚩 Input for safety meetings on board.
- 🚩 Lesson material for educational institutions.
- 🚩 As a basis for procedures and work instructions.

This publication is developed by:

| | |
|-------------------|---|
| Arno de Ruijter | HSEQ Manager - RBC |
| Fop Mooyaart | Sales Firefighting, Rescue & Safety - Dräger Nederland B.V. |
| Francis Schapers | Captain-owner - MCS Duancis |
| Harm Bergsma | Coordinator/Teacher inland shipping - STC |
| Jan Klonki | Manager QEHS Shipping - Imperial Logistics |
| Marnix de Bakker | Preventionmanager - EOC Schepenverzekering |
| Norbert van Lopik | VTS Manager – RWS & Brandweer Midden en West Brabant |
| Willem Meerkerk | Senior Inspector/expert Inland Shipping - Inspectie Leefomgeving en Transport |

TABLE OF CONTENTS

| | |
|--|--|
| 1. INLEIDING | FOUT! BLADWIJZER NIET GEDEFINIEERD. |
| 1.1. Waarom dit document? | Fout! Bladwijzer niet gedefinieerd. |
| 1.2. Hoe dit document te gebruiken? | Fout! Bladwijzer niet gedefinieerd. |
| 2. DE BRANDDRIEHOEK | FOUT! BLADWIJZER NIET GEDEFINIEERD. |
| 3. BLUSMIDDELEN | FOUT! BLADWIJZER NIET GEDEFINIEERD. |
| Overzicht brandblusmiddelen en gebruik..... | Fout! Bladwijzer niet gedefinieerd. |
| Onderhoud blusmiddelen..... | 8 |
| Rookmelder..... | Fout! Bladwijzer niet gedefinieerd. |
| 4. TYPE BRAND | 9 |
| Broei in machinekamer of in dekkisten | 9 |
| Apparatuur (motor) | 9 |
| Elektriciteit..... | Fout! Bladwijzer niet gedefinieerd. |
| Heet werk/brandgevaarlijk werk | 11 |
| Lading..... | Fout! Bladwijzer niet gedefinieerd. |
| 5. BRAND EXTERN: AAN DE WAL/ANDER SCHIP | 12 |
| 6. SPECIFIEKE LOCATIES | FOUT! BLADWIJZER NIET GEDEFINIEERD. |
| Woning en stuurhut..... | 13 |
| Auto/bijboot | 13 |
| 7. BRANDOEFENINGEN | FOUT! BLADWIJZER NIET GEDEFINIEERD. |
| GERAADPLEEGDE BRONNEN | 14 |
| Wet-, regelgeving en normen..... | Fout! Bladwijzer niet gedefinieerd. |
| BIJLAGE 01: VASTE BLUSGASINSTALLATIE | 15 |
| Bediening blusgasinstallatie | 15 |
| BIJLAGE 02: BRAND OEFENING | 16 |
| Scenario..... | 16 |
| Antwoordkaart..... | Fout! Bladwijzer niet gedefinieerd. |

1. INTRODUCTION

1.1. Why this document?

Fires can occur on board. By means of this *Best Practice Guidance (BPG)* of the Platform Zero Incidents we would like to draw attention to two parts, namely the prevention of fire and the fight against it.

The most important thing is to prevent fires and this document provides a summary of the type of fires that can occur and how these can be prevented.

The second point is the fight against the fire by the crew. In case of fire, the crew is initially dependent on themselves. This document provides guidelines on which steps can be taken.

1.2. How to use this document?

This document does not replace current systems or documents that are already available on board, such as emergency plans. Also pay attention to special circumstances such as the use of LNG or hydrogen supply. These exceptions have not been included. Consider prescribed legislation that may differ from the general scenarios described in this document.

In addition, this document is not all-encompassing and there may be situations that are not covered in this document.

You can use the document as a reference, but also for familiarization with the barge and/or to train your crew members. You can also handle the document during safety meetings with your crew.

It can increase safety awareness on board and thus prevent the risk of accidents.

If you have suggestions to further improve this document, please contact the Zero Incidents Platform.

Platform Zero Incidents

www.platformzeroincidents.nl

info@platformzeroincidents.nl

@PZI_tweets

+31 (0) 10 297 40 22


2. THE FIRETRIANGLE

Fire can occur when three elements come together: a flammable substance, an ignition source and oxygen. This is also called the fire triangle.

The condition here is that the heat is at least up to the ignition temperature of the flammable substance.

With a flammable substance you can think of dangerous substances that are being transported, but also cleaning cloths, cleaning products or even (parts in) electronic equipment.

In the following sections we will go deeper into the type of fires that can occur on board. Although an attempt has been made to name all types of fires, there may be situations that are not foreseen. Take this into account and be aware of the 3 elements from the fire triangle.



When there is a fire on board, this can in some cases be extinguished by the crew. However, in many cases it is necessary to call emergency services. Do this quickly!






It may be useful to enable location determination on the mobile phone, sometimes the exact location can be shared with emergency services.

Also contact the office / owner (if relevant). Follow the emergency plans.

3. EXTINGUISHERS

Overview of fire extinguishers and use

Below an overview of the extinguishers that could be on board and an indication for which type of fires they can best be used.

| |  |  |  |  |  |
|---------------------------------------|--|---|--|---|---|
| Substance | Materials | Liquids | Gases | Flammable metals | Oils and fats |
| Examples | Wood, paper, textiles | Oil, petrol, fats | Butane, propane, natural gas | Magnesium, aluminum, sodium | Frying fat |
| Type of extinguisher | | | | | |
| Water | ✓ | ✗ | ✗ | ✗ ⚡ | ✗ ⚡ |
| ABC-powder* | ✓ | ✓ | ✓ | ✗ | ✗ |
| D-powder* | ✗ | ✗ | ✗ | ✓ | ✗ |
| CO ₂ | ✗ | ✓ | ✓ | ✗ ⚡ | ✗ |
| Spray foam | ✓ | ✓ | ✗ | ✓ | ✓ |
| Fire blanket | ✓ | ✓ | ✗ | ✗ | ✓ |
| Fixed extinguishing gas system | For use in case of a fire in the engine room. For more information see Appendix 01: . | | | | |
| Sprinklers | Serves to cool the deck, cargo or extinguish in living areas (in case of passenger ships). | | | | |

✓ = suitable extinguisher for this type of fire

✗ = unsuitable extinguisher for this type of fire

⚡ = dangerous to use extinguisher for this type of fire

* = Shake every three months to prevent clumping. Also include this in the monthly maintenance lists.

Maintenance extinguishers

During the year, fire extinguisher should be checked for pressure loss, sealing, damage and of course for actual presence. Powder extinguishers should be shaken every three months to prevent clumping. Also include this in the monthly maintenance lists.

In addition, fire extinguishers should hang, because an extinguisher standing on the ground can fall over and because can then be moved less easily.

Even a fixed extinguishing gas system must be checked regularly for pressure loss and for pressure increase. Pressure increase can occur because the room in which the installation is located heats up. Certainly during summer time, it can happen that due to rising temperature the pressure becomes so high that the breaking plate in the valve breaks and all extinguishing gas is expelled. In addition to the high costs, there is also the chance that the engines (if they suck their air out of the engine room) will stop.

Smoke alarm

Provide suitable smoke and fire detectors and check them regularly for operation.

4. TYPE OF FIRES

Spontaneous combustion in machineroom or inside deck box

Causes

Spontaneous combustion in the engine room or in the deck box occurs regularly. The combustible products on, for example, cleaning cloths that are stored in buckets or boxes can reach their ignition temperature (flash point). The heat that is released during the drying of these oils cannot escape (especially if a cloth is stored somewhere as a wad). It can happen that the temperature rises to a point that the material smolts and a fire occurs.

Heat can accelerate this. In engine rooms, and in the summer on deck, it can get very hot which can accelerate heating. When oxygen is present, a fire may occur.

Prevention

Spontaneous combustion can hardly be prevented, but a number of measures can be taken:

- Remove polishing cloths as quickly as possible;
- Put buckets and deck boxes in as cool a place as possible;
- Separating cloths from other means such as paint, bottles of thinner, brushes, etc. ;
- Let the cloths dry fully;
- Be alert when opening a closed bucket / box, oxygen will be added which may cause ignition;
- Take care that when there are plastic bags in a container, the lid may not close properly and oxygen may get in;
- Keep the amount of product as minimal as possible (hand washing with less flammable products and use cloths as little as possible when cleaning);
- Painting the deck boxes in a light color (they become less hot than dark colors);
- Insulate deck boxes;
- Be aware of the ignition points of the products used;
- Check buckets and deck boxes regularly on spontaneous combustion.

Measures for control

When spontaneous combustion or a fire happens, the first step is to remove the oxygen supply. This can be done by closing the box or bucket well or by using an extinguisher.

Equipment (engine)

Causes

Most equipment becomes warm when in use. In addition, flammable liquids are often used, for example to lubricate or clean. This combination (together with oxygen) can lead to ignition. A number of causes:

- Start motor that lingers;
- Slippage of v-belts;
- Leakage / mist formation;
- Smoking in the engine room (cigarette butts or sparks);
- Flammable products on hot surfaces (oil or other dirt on the engine, a cloth / rag);
- Filters operating poorly;
- Sealed air supply.

Prevention

Ignition of equipment can be prevented by taking the following measures:

- Proper cleaning of equipment;
- Clean up cloths and (cleaning) agents after use;
- Communicate well when maintenance is done (also use the Lock-out / Tag-out method, a procedure for locking and marking equipment or piping systems in maintenance to prevent unexpected activation);
- Keep the air supply to the engine room free;
- Check the filters and tubes and replace them on time.

Measures for control

When fighting a fire in the engine room, a number of factors are very important. There is gas detection devices that warns the crew. It is important to switch off equipment (you take the heat source away) and small fires can be extinguished manually if the fire occurs when you are in the engine room.

If a fire arises and there are **no crew members in the room**, the fixed extinguishing gas system can be used (if present). Ensure that the ventilation openings are closed. See Appendix 01 on the use of the fixed extinguishing gas system.

Electricity

Causes

An electricity fire can have the following causes:

- Dirt, such as dust or oil or other liquids;
- Loose outlets;
- Heat in the electricity cabinet;
- Short circuit;
- Friction / fire in the wheelhouse column (cables that tear or heat up);
- Damaged cables;
- Cables that heat up, for example reels and plugs.

Prevention

An electricity fire can be prevented by keeping electricity clean and checking regularly for damage. Rollout the cables completely when using them, for example with reels. Do not tie cables together, but within moving parts, put a sock around them. Ensure earthing of the equipment.

In addition, when something goes wrong with the electricity, there is often a particular smell. Be aware of this.

Measures for control

There are a number of measures that can be taken when there is a fire:

- Remove the power from the relevant device / circuit;
- A powder extinguisher can be used, but can cause collateral damage to the electricity;
- Use a foam extinguisher to fight the fire;
- CO2 extinguisher as an addition to the powder or foam extinguisher;
- If the fire is of such a size that hand extinguishers are not suitable, the extinguishing gas system can be used (if present). See Appendix 01 on the use of the fixed extinguishing gas system.

Hot work

Causes

Hot work or other fire hazardous activities can immediately cause a fire. Also, indirect causes such as sparks can cause ignition. It is therefore important to be aware of this. Below are a number of activities that are associated with fire hazardous activities:

- Welding;
- Soldering (or soldering iron that is somewhere against);
- Scaling;
- Sharpening;
- Sanding;
- Paint stripping;
- Irradiation of heat, for example when doing carpentry or drilling;
- Heat and / or sparks are generated by friction, so that they can serve as sources of ignition (and other means or gasses in the environment can ignite);
 - Smoldering of paint and rust;
 - Wood and insulation that catches fire due to sparks;
 - Thinner or oil stains that catch fire due to the heat.

Prevention

For the prevention of ignition of substances, please take into account the following points:

- Use a permit to work;
- Get approval from the captain and inform other crew members of the activity to be carried out;
- Ensure earthing of the barge;
- Use of spark-free tools;
- Wear antistatic clothing;
- Work in a clean work environment;
- Carry out gas measurements where necessary and ensure a safe environment;
- Be aware of the environment (materials in the environment and adjacent spaces);
- Remove flammable materials, cover the environment with the proper means;
- Cool the room and elements if possible;
- Clean and tidy up, also pay attention to how you leave the area behind (for example do not leave hot appliances).

Measures for control

Before starting activities, ensure that there is a fire watch if activities are carried out in confined spaces. Also, close fire doors and keep extinguishing equipment ready so that in case of emergency the damage is limited.

Cargo

Causes

The cargo that is being transported may ignite because of the following reasons:

- Incineration and self-combustion:
 - Friction that can cause heat and fire;
 - Warming up of the cargo causing (flammable) gases to be released that ignite by a low temperature.
- Ignition of:
 - Explosive / flammable gases;
 - Scrap, paper, wood;
 - Drilling and turning curls.

Prevention

Fire in cargo can be prevented by taking into account the following elements:

- Ventilate, cool / cover the load (remove ignition sources);
- Earthing of the ship;
- Carry out gas measurements and checks in order to take timely measures if necessary;
- Product knowledge to take timely measures. For example, specific measures may apply to the load (also on non-ADN products).

Measures for control

If a fire occurs, it is necessary to extinguish the fire. This can be done, for example, by using the sprinklers.

5. EXTERNAL FIRE: ON SHORE/OTHER VESSEL

Be aware that fire can also take place somewhere else. For example, when loading and discharging activities takes place and there is a fire on the shore. Keep communication open with the parties so that the right actions can be taken; provide assistance, keep distance or evacuate. Keep the following matters in mind:

- The position of the barge, is the barge up or downwind;
- The dinghy is ready for use;
- Be aware of the environment;
- Are you familiar with the alarms and escape routes ashore?

6. SPECIFIC AREAS

Living areas and wheelhouse

Fire can also break out in the living areas. Possible causes and measures are listed below.

Causes

- Heating of chargers or devices that are being charged;
- Dust filters in dryers;
- Dirty extractor hood;
- Polluted (bathroom) fans;
- Frying pan of which the (old) fat is overheated;
- Electricity (see electricity);
- Leakage of gas installation.

Prevention

- Charging equipment or equipment that is switched on or left unattended in standby mode;
- Maintenance of household appliances according to the manual;
- Use of original supplied parts;
- Do not leave open fires (candles, gel fireplaces, etc.) unattended;
- Heating appliances must be fixed.

Measures for control

First switch off equipment and/or turn off the gas supply during gas fires. Then use manual extinguishers and/or a fire blanket.

Car/dinghy

Be aware of the following:

- Gas formation in the hood of the engine of the dinghy;
- The fuel tanks.

7. FIRE DRILLS

In order to be well prepared for emergency situations like a fire on board, it is important to practice regularly. This way everyone knows what the expectations are, what actions need to be taken and by whom. It also provides more clarity about what resources are available, where they are located and how to use them.

Every second counts.

An example of a fire drill is given in Appendix 02.



CONSULTED SOURCES

Laws, regulations and standards
CESNI

APPENDIX 01: FIXED EXTINGUISHING GAS SYSTEM

Make sure that the instruction is visible and in a language that the captain can understand.

The instructions must include the following elements:

- Activation of the fixed extinguishing system into operation;
- The necessity of checking that all persons have left the area;
- Before activating the fixed extinguishing system, the engine in the area that draw in air from the room must be taken out of operation.
- Proper handling of the crew in case of activation and entering the space after activation or diffusion, in particular with regard to the possible presence of hazardous substances;
- Proper handling of the crew in the event of a breakdown in the extinguishing system.

Activation fixed extinguishing system

When it is decided to use the fixed extinguishing system, follow the instructions carefully. Below an example of an instruction manual:

1. Evacuate the area because of toxic gases and the expulsion of oxygen.
2. Close doors and openings to prevent the extinguishing gas from leaving the protected area and the entering of fresh air.
3. If engines use air from the protected area: switch off engines.
4. Open the control box and the alarm sounds and ventilation stops.
5. Pull handle.
6. Installation is in operation.
7. If the extinguishing system does not function: leave the doors and openings closed and do not enter the room.
8. Because of toxic gases, only enter the room after it is released. Release can be done by agencies such as the fire brigade, port, safety advisor and environmental service. They have the right measuring instruments and protective respiratory protection and clothing for this.

APPENDIX 02: FIRE DRILL

Provided by Emprove.

Scenario



Drill B-MK-01

Scenario

Fire in engineroom front.

Description

During the loading of containers the barge is moored at the terminal. The captain is busy with the administration behind the computer in the wheelhouse. The helmsman is off duty and is sleeping. One of the sailors supervises the loading of the containers and is on deck. The other sailor is busy changing the oil filters of one of the generators in the engine room of the stern.

A leaking fuel line in the engine room of the fore section sprays a mist of gas oil on the rotating generator. Over time, the leaked fuel heats up to a point that it catches fire. The fire then switches to a number of cardboard boxes that are stored there and gives a considerable smoke development.

The sailor on deck, who supervises the loading, sees the smoke coming out the ventilation openings of the engine room.

Discuss the following questions:

1. What actions does the sailor have to take?
2. How can the fire be fought safely?
3. Which persons have which role?
4. How and who are informed?
5. What is described in the procedures for the above situation?
6. What is arranged in the emergency plan?
7. Which PPE can be used?

In which form is the exercise performed?

Incident discussion Physical exercise

Scenario fire in engineroom 01

